

Needed work and equipment for Capron

Floor in both cafeteria bathrooms it is coming up

Heat in gym both units to old cant get parts for them

Grease traps need to get pumped out

Bathroom vents need to be cleaned out

Drains need to get jetted out

Room door locks

Door closers

A/C units in rooms

Water running in the basement

Doors need to get trimmed

Gutters need to be cleaned out

Roof leaks

Ceiling tiles missing or bad

Main entrance doors bad

Entrance doors f&g bad need to be replaced

Bathroom upper urinals need to be replaced

6 sink faucets need to be replaced

Air leaks in upper heating units

Vacuum was to get replaced

Snowblower needs to be replaced need a 3 stage when this happens used my blower last year

salt spreader used my spreader last year it is what is needed here

water filter system for school

Freezer door need to replace the freezer

Back stop fence need to finish the project before it falls down

P.K playground fence needs to be done right (the way it was to be made the 1st time)

pile of old wood on the side of school

Cement needs to be repaired

Roof over the holes on the stage

Ceiling tiles on stage

Elc. Outlets in teacher lounge

Exhaust fan in kitchen

strippingof parking lot and crosswalks

pipng on gutter downspouts

Steam piping in tunnel looks like leaking

Capron Freezer 2019

New Freezer Door							
	Norlake Surface Mount Freezer Door						3214
		30X72					
New Freezer							
	Koolmore 82" 3 door S/S Upright Commercial Upright						3699
		72 cu.ft.					
	ATOSA Comm. 3 door Freezer top mount						4120
	ATOSA Comm. 3 door Bottom mount freezer						4371
	Central 69k-036 72 cu ft 3 door						4398.9
	Central 675-408 3 door						5900.16
	Central 633-120 Hoshizaki F3A-fs						64776.72