ATTACHMENT X-C: Cafeteria at Manchester Elementary

Suggested Motion: Move to approve renovation of cafeteria at Manchester

Elementary

Recommended Action: Approve as presented

The Facilities Committee reviewed projects for this summer, including some significant roof work at Capron and NBMS. The committee wanted to make sure the whole Board was in support of moving forward with work on the Manchester cafeteria. All of the staff at the Committee meeting, Kristi Crawford, Jeannine Plath, Jim Novak and Steve Baule spoke to the significant health and workplace safety issues at the Manchester cafeteria. Below is a list of some of the violations and concerns raised. The exact scope of the project won't be known until the architects develop a framework from which to bid the project. Currently the rough estimate for the project is about \$177,000. The staff strongly recommends that this project be completed during the summer of 2012.

## Manchester Kitchen Illinois Department of Health Department Violations

- 1. No hand wash sink
- 2. No separate food prep sink
- 3. No three compartment sanitary sink with runoff boards
- 4. Sinks do not have open site drains
- 5. No exhaust hood over stove
- 6. No fire suppression system over stove and cooking equipment
- 7. No exhaust hood over dishwasher
- 8. Dry food storage intermixed with maintenance storage
- 9. Dishwasher does not wash properly, written up by IDPH
- 10. Freezers are not commercial grade units
- 11. Food serving table not compliant with IDPH code (Requires sneeze guards)
- 12. Food preparation surface materials and storage cabinet materials not IDPH compliant

## Manchester Kitchen Safety Issues & Concerns

- 1. Electrical disconnect is too close to existing sink
- 2. Receptacles are not ground fault
- 3. Existing dishwasher is at floor level causing potential for bending and lifting injuries
- 4. Dishwasher worn out and in need of replacement
- 5. Inadequate space for safe and healthy food preparation and food serving
- 6. Kitchen cannot be locked or secured from unauthorized personnel
- 7. Serving table needs proper electrical service