

ATTACHMENT NO. X-E: Sanitary Sewer Line Replacement - PGE

Potential motion: Approve to move forward with the District Architect to prepare bid documents to replace the sanitary sewer lines leading out of the Poplar Grove Elementary School.

Recommended action: Approve the motion

### Sanitary Sewer Line Replacement

Poplar Grove Elementary school has two sewer lines leading to the village. During the Village's Ray Street repair work last fall it was discovered the Poplar Grove School's two sewer lines are slowly clapping due to material & age. If left unattended, failure of either line will essentially close the school for use. This is a proactive step to keep that from happening.

This project requests approval to have the District Architect investigate the problem and prepare documents for the replacement and possible consolidation of those two sanitary sewer lines.